

Client: L & S WASTE MANAGEMENT LTD
 PEGHAM INDUSTRIAL ESTATE
 LAVEYS LANE
 FAREHAM
 HAMPSHIRE
 PO15 6SD
 F.A.O. STEVE KEW
 Copies To:

Lab No.: **D2470**

PARTICLE SIZE DISTRIBUTION CERTIFICATE


Project: **AGG. TESTING: L & S SEPTEMBER 2015**
 Location: **STOCKPILE ON SITE**
 Material: **TYPE 1 SUBBASE**
 Specification: **DTp SHW CLAUSE 803 SUPPLIER DECLARED SPEC.**
 Contractor: **Not Applicable**
 Supplier/Plant: **L & S WASTE MANAGEMENT - FARLINGTON REDOUBT**
 Date Sampled: **01/09/2015**
 Sampled By: **SM**
 Sample Type: **BULK**
 Sample Mass: **47061g**

Ticket No.: **N/A**
 Date Received: **01/09/2015**
 Tested By: **BL**
 Date Tested: **09/09/2015**
 Site Ref.: **SM2**

TEST RESULTS

Preparation Method: BS EN932-2: 1999. Test Method: BS EN933-1: 2012

Sieve	Passing %	Specification
63mm	100	100
31.5mm	90	75 - 99
16mm	68	48 - 78
8mm	55	27 - 57
4mm	43	13 - 43
2mm	35	10 - 36
1mm	27	8 - 28
0.063mm	6	0 - 9
P 16mm R 8mm	13	7 - 30
P 8mm R 4mm	12	7 - 30



Test	Result	Specification
Moisture Content (%) :	11.1	

Category : **A**
This sample complies with the above specification.



Signed:.....*[Signature]*.....
 Approved Signatories: *M. Mullane*/E. Frost
 Date:.....*14/9/15*.....

Opinions and interpretations expressed herein are outside the scope of UKAS accreditation.
 No. 0045