




Ridgewood House  
The Ridge  
Chipping Sodbury  
Bristol  
BS37 6AY

## Particle Size Distribution Report

**Product:** 10/63mm Limestone  
**Material Code:** 70000192  
**Supplied by:** Whatley  
**Customer:**   
**Site:**   
**Ticket Number:**   
**Testing Laboratory:** Whatley  
**Material type:** HGS / Limestone  
**Job Type:** 100/General  
**Test Method:** Dry sieving entire sample  
**(To BS EN 933-1 : 2020)**

Sampled to: BSEN 932-1 : 1997  
 Prepared to: BSEN 932-2 : 1997



Sample Information		Sieve Size (mm)	Percentage Passing (%)	Spec limits (%)	Complies
Sample number	AGG-50807	100	100	-	-
Sampled by	Luke Menhennet	90	100	-	-
Date Sampled	25/01/2022	80	100	-	-
Date Tested	26/01/2022	75	100	-	-
Sample location	Level 8	63	100	90 - 100	Yes
Moisture Content (%)	0.5	50	76	-	-
Flakiness Index		40	71	60 - 80	Yes
Flakiness Specification		31.5	59	-	-
Compliance Specification	Yes	20	29	15 - 30	Yes
Remarks		16	15	-	-
		14	11	-	-
		10	3	0 - 5	Yes
		6.3	1	-	-
		4	1	-	-
		2	1	-	-
		1	1	-	-
		0.5	1	-	-
		0.063	0.3	-	-

Results shown on this report only relate to the sample being tested and at no point did the laboratory deviate from the test method as stated above.

Signed: Area Technical Manager

Issue Date :10/03/2022