




Ridgewood House
The Ridge
Chipping Sodbury
Bristol
BS37 6AY

Particle Size Distribution Report

Product: 4/20mm Limestone
Material Code: 70000008
Supplied by: Whatley
Customer:
Site:
Ticket Number:
Testing Laboratory: Whatley
Material type: HGS / Limestone
Job Type: 100/General
Test Method: Splitting dry sample - no washing
(To BS EN 933-1 : 2020)

Sampled to: BSEN 932-1 : 1997
 Prepared to: BSEN 932-2 : 1997



Sample Information	
Sample number	AGG-54878
Sampled by	Luke Menhennet
Date Sampled	07/03/2022
Date Tested	10/03/2022
Sample location	Blend 125
Moisture Content (%)	0.8
Flakiness Index	
Flakiness Specification	
Compliance Specification	Yes
Remarks	

Sieve Size (mm)	Percentage Passing (%)	Spec limits (%)	Complies
40	100	100	Yes
31.5	100	98 - 100	Yes
20	98	90 - 100	Yes
16	88	-	-
14	80	-	-
12.5	69	-	-
10	46	25 - 60	Yes
8	37	-	-
6.3	30	-	-
5	21	-	-
4	14	0 - 15	Yes
2	4	0 - 5	Yes
1	2	-	-
0.5	2	-	-
0.25	1	-	-
0.125	1	-	-
0.063	0.9	0 - 4.0	Yes

Results shown on this report only relate to the sample being tested and at no point did the laboratory deviate from the test method as stated above.

Signed: Area Technical Manager

Issue Date :10/03/2022