

County Highways Laboratory

Stockbridge Road, Micheldever Station, Hampshire, SO21 3BB

Telephone:01962 774502

email: CountyHighwaysLab@hants.gov.uk

**Hampshire**
County Council

Client: L & S Waste Mangement Ltd Pegham Industrial Estate
Laveys Lane
Fareham
Hampshire
PO15 6SD

Lab No.: A0375

F.A.O: Steve Kew

Particle Size Distribution Report

Project: Aggregate testing: L & S May 2022

Location: 6F5 Stock

Material: Crushed demolition

Specification: Dft SHW Table 6/5 6F5 Capping

Contractor: N/A

Supplier/Plant: L & S - Sholing

Date Sampled: 04/05/2022

Date Received: 04/05/2022

Sampled by: JH

Tested by: DS

Sample Type: Bulk

Date Tested: 11/05/2022


Test Mass (g): 36641

Site Ref.: JH4

Test method: BS EN 933-1: 2012 Sampling Method: BS EN 932-1:1997

Preparation Method: BS EN 932-2: 1999

Sieve Size (mm)	Percent passing	Specification
125	100	100.0
80	94	75.0 - 99.0
40	68	50.0 - 90.0
20	48	30.0 - 75.0
10	37	15.0 - 60.0
2	23	<= 35.0
0.063	3.6	<= 12.0



Moisture content (%) 5.1

Uniformity Coefficient 155



0645

Remarks The sample complies with the specification

Signed	
Date	12/05/2022
Approved	E. Frost

note: County Highways Laboratory only accepts responsibility for the accuracy of the results contained in this report. No responsibility can be accepted for the results being representative of the material or items sampled unless sampling has been carried out by County Highways Laboratory staff. This result may not be reproduced either in part or in full without the written permission of the County Highways Laboratory. The results stated in this report are only related to the items tested. For samples taken by the Client the results stated in this report are only related to the sample/s as received.