

**County Highways Laboratory**

Stockbridge Road, Micheldever Station, Hampshire, SO21 3BB

Telephone:01962 774502

email: CountyHighwaysLab@hants.gov.uk

**Hampshire**  
County Council

Client: L & S Waste Mangement Ltd Pegham Industrial Estate  
Laveys Lane  
Fareham  
Hampshire  
PO15 6SD

Lab No.: A0362-1

F.A.O: Steve Kew

**Particle Size Distribution Report**

Project: Aggregate testing: L &amp; S April 2022

Location: Processed Stock

Material: Crushed demolition

Specification: SHW Table 6/5 Class 6F4

Contractor: N/A

Supplier/Plant: L&amp;S Portsdown Hill

Date Sampled: 06/04/2022

Date Received: 06/04/2022

Sampled by: JH

Tested by: DS

Sample Type: Bulk

Date Tested: 12/04/2022


Test Mass (g): 17764

Site Ref.: JH3

Test method: BS EN 933-1: 2012 Sampling Method: BS EN 932-1:1997

Preparation Method: BS EN 932-2: 1999

Sieve Size (mm)	Percent passing	Specification
63	100	100.0
31.5	81	75.0 - 99.0
16	60	50.0 - 90.0
8	42	30.0 - 75.0
4	27	15.0 - 60.0
1	20	<= 35.0
0.063	7.0	<= 15.0



Moisture content (%) 8.8

Uniformity Coefficient 118



0645

Remarks The sample complies with the specification

Signed	
Date	09/05/2022
Approved	E. Frost

note: County Highways Laboratory only accepts responsibility for the accuracy of the results contained in this report. No responsibility can be accepted for the results being representative of the material or items sampled unless sampling has been carried out by County Highways Laboratory staff. This result may not be reproduced either in part or in full without the written permission of the County Highways Laboratory. The results stated in this report are only related to the items tested. For samples taken by the Client the results stated in this report are only related to the sample/s as received.